

Fire formal interpretations

17 August 2017

FI-129

NZS 4514:2009 *Interconnected Smoke Alarms for Houses* - Clause 5.1 and Referenced Documents

Question:

Are detectors that comply with the following new standards permitted?

- a) ISO 12239:2010
- b) AS 3786:2015
- c) CAN/ULC S531 (3rd edition) 2014
- d) UL 217 (8th edition) 2015
- e) BS EN 14604:2005

Interpretation issued by the Alarms and detection group:

Yes

Notes:

BS 5446 part 1:2000 has been withdrawn and replaced by BS EN 14604:2005.

EN 14604:2005 is still current.