



17 December 2004

FI 005

Question:

NZS 4541

**Interpretation:**

Issued by the Fixed Fire Protection Group

Clause: 607.1.9

Yes.

Is it the intent of 607.1.9 that the device or “defect signal” which indicates that the pump is running shall indicate continuously as long as the pump is running?

**Reviewed in 2008 and deemed applicable to NZS 4541:2007**