



01 July 2004

Fl 010

Question:

Interpretation:

Std: NZS 4541:2003

Issued by the Fixed Fire Protection Group

Is it the intent of the Standard that clause 902.3.7 should negate the requirements of clause 902.3.4.

No, both clauses must be complied with.

Reviewed in 2008 and deemed not applicable to NZS 4541:2007 (applies to 2003 edition)