



01 July 2004

FI 015

Question:
Std: NZS 4541

Interpretation:
Issued by the Fixed Fire Protection Group

Is it the intent of the standard that 205.1.3 permits independent fire-cells within a building provided they meet the intent of 205.2.2?

Yes

Reviewed in 2008 and deemed applicable to NZS 4541:2007