



*01 July 2004*

*Question:*

Std: NZS4515

*Interpretation:*

Issued by the Fixed Fire Protection Group

*Fl 022*

Is it the intent of the scope of NZS 4515 to cover hospitals which contain medical facilities such as operating theatres, x-ray rooms, scan rooms, etc? No.