



**01 July 2004**

**Question:**

Std: NZS4541

**FI 026**

**Interpretation:**

Issued by the Fixed Fire Protection Group

Is it the intent that clause 605.1.9 be applied to private Class C water mains that were previously approved public water supplies (hospitals and universities)?

Any new installations (new sprinkler control valve installations) on the site shall comply with system and hydrant demands in accordance with the Standard.

**Reviewed in 2008 and deemed applicable to NZS 4541:2007**