



14 August 2007

FI 078

Question:

Interpretation:

Std: NZS 4541

Issued by the Fixed Fire Protection Group

Appendix G

Was it the intention of the committee that an SSC can require from contractors higher levels of documentation, training and qualifications than is specified in NZS 4541:2003 Appendix G which is a Normative Appendix?

No.

Reviewed in 2008 and deemed not applicable to NZS 4541:2007 (applies to 2003 edition)