

Fire formal interpretations



23 July 2020

FI-140

NZS 4541:2020 *Automatic fire sprinkler systems* – Clause 6.4.1.4

(to be completed by Standards New Zealand)

Question:

Was it the intent of the committee that NZS 4541:2020 Clause 6.4.1.4 *Pipework*, that “the pipework of a connection to a town’s main supply shall comply with 4.3.11.2”?

Interpretation issued by the Fixed fire protection group:

No. The intent of the committee is that NZS 4541:2020 Clause 6.4.1.4 *Pipework* *that* “the pipework of a connection to a town’s main supply shall comply with 4.3.1.1”.