



29 August 2005

FI 044

Question:

Std: NZS 4512

Interpretation:

Issued by the Alarms and Detection Group

Section 216

Are detectors that comply with the following new standards permitted? **Yes**

- a) Heat Detectors (216.1)
ISO 7240-5:2003
AS 7240.5-2003
- b) Smoke Detectors (216.2)
ISO 7240-7:2003
AS 7240.7-2004
- c) CO Detectors (216.4)
ISO 7240-6:2004
- d) Multisensor Detectors (new category)
ISO 7240-15:2004
AS 7240.15-2004