



10 November 2006

Question:

Std: NZS 4512

Interpretation:

Issued by the Alarms and Detection Group

FI 068

405.2.1(q)

For wardrobes smaller than 6 m³, to escape needing a detector inside must the orifice vent "at the top into the room" as is required for cupboards in 405.2.1(s)?

Yes