



10 November 2006

Question:

Interpretation:

FI 069

Std: NZS 4512

Issued by the Alarms and Detection Group

The EWIS installation standard AS 2220.2 - 1989 (referenced in 406.8 and 501.2) has been superseded by AS 1670.4 - 2004 *Sound systems and intercom systems for emergency purposes*. Is this an acceptable alternative?

No.

AS1670.4 – 2004 has significant differences and requirements additional to AS 2220.2 – 1989, some of which contradict NZS 4512:2003.

NOTE:

AS 2220.2 – 1989 is also cited in the NZBC Approved Documents.