



26 February 2007

FI 073

Question:

Std: NZS 4512

Interpretation:

Issued by the Alarms and Detection Group

405.4

a) Do detectors in a ceiling or concealed space require individual indicators?

a) Yes. This indicator may be located either on the detector or (suitably labelled) in an adjacent normally-accessible space.

b) May one indicator in an adjacent normally-accessible space provide indication for multiple detectors in a ceiling or concealed space?

b) Yes, however such detectors also require individual indicators.