



01 July 2004

Question:

Std: NZS4541

Interpretation:

Issued by the Fixed Fire Protection Group

FI 011

In 605.1.10 does the expression “hydrants” include hydrants on a riser in a multi-storey building?
This now relates to clause 605.1.9 – 2003.

Yes, but only applicable to “wet riser” hydrant systems.