



**FORMAL
INTERPRETATIONS**

01 July 2004
Question:
Std: NZS 4541

Interpretation:
Issued by the Fixed Fire Protection Group

FI 013

Is it the intention of the Standard that types of water supply other than those listed in 603.2 are acceptable as primary water supplies? No.

Reviewed in 2008 and deemed applicable to NZS 4541:2007