



01 July 2004

FI 016

Question:

Std: NZS4541:2003

Interpretation:

Issued by the Fixed Fire Protection Group

Is it the intent of NZS 4541 to provide for drenchered internal fire separations?

No

Should a sprinkler system be permitted to provide water for such internal drenchers?

Yes, but only in compliance with 602.1.

Reviewed in 2008 and deemed not applicable to NZS 4541:2007 (applies to 2003 edition)