



01 July 2004

Question:

Std: NZS4541:2003

Interpretation:

Issued by the Fixed Fire Protection Group

FI 018

Is it the intent of 908.2.1 (b) that the evidence referred to as 'adequately documented evidence' includes the latest published information?

Yes. Early Suppression Fast Response sprinklers are an emerging technology and dated information may have been superseded.

*Reviewed in 2008 and deemed not applicable to NZS 4541:2007
(applies to 2003 edition)*