



01 July 2004

Question:

Std: NZS4515

Interpretation:

Issued by the Fixed Fire Protection Group

FI 021

In terms of 4.4.1 are carports attached to a building structure to be treated as vehicle garage?

Yes.