



01 July 2004

FI 025

Question:

Std: NZS4541:2003

Interpretation:

Issued by the Fixed Fire Protection Group

Is it an acceptable alternative to Clause 605.1..9.2 (b) to certify the water supply of the sprinkler and hydrant flow when the flow demand is available at less than the sprinkler design pressure, but greater than 1 bar at the street?

Yes, as allowed by SNZ PAS 4509.

Reviewed in 2008 and deemed not applicable to NZS 4541:2007
(applies to 2003 edition)