



*01 July 2004*

*Question:*

Std: NZS4541

Is it the intent of NZS 4541 that clauses 605.1.7 and 605.1.8 (connections for industrial and non-industrial uses) and clause 605.1.9 (connection of hydrants) be applied to all new sprinkler systems on a site that had a public water supply that has changed to private ownership?

**Interpretation:**

Issued by the Fixed Fire Protection Group

Yes.

*Reviewed in 2008 and deemed applicable to NZS 4541:2007*

*FI 027*