



**FORMAL  
INTERPRETATIONS**

**14 August 2007**

**FI 081**

**Question:**

**Interpretation:**

**Std: NZS 4515**

**Issued by the Fixed Fire Protection Group**

Clause 3.6.4 ( c) identifies the requirement for the installation of a low water pressure detector (pressure switch) as part of the installation control valves.

Yes.

The Standard does not identify the pressure at which this device shall operate.

Shall this device be set to operate before the system pressure drops to the highest design pressure?