



3 July 2012

FI-105

Question:

NZS 4541:2007 *Automatic fire sprinkler systems* – clause 1202.6 (a)

Interpretation:

Issued by the Fixed Fire Protection Group

Do the requirements detailed in regard to the overhaul of water supply check valves apply to check valves fitted to pumped water supplies, where the pump set enclosures are remote from individual control valve enclosures?

Yes. Water supply check valves shall be overhauled 4-yearly, regardless of location.