

Fire formal interpretations

24 September 2014

FI-115

NZS 4510:2008 *Fire hydrant systems for buildings* – Clause 5.3.1

Question:

Does formal interpretation [FI-112 Fire Service inlet couplings](#) on NZS 4541:2013, published 4 July 2014, equally apply to Clause 5.3.1 of NZS 4510:2008?

Interpretation issued by the Fixed fire protection group:

Yes, it also applies to NZS 4510:2008.