

New Zealand Standard

## **Glazing in buildings**

Part 2: Insulating glass units

**Superseding NZS 4223.2:1985** 

## NZS 4223.2:2016

## **Single User PDF Terms & Conditions**

You have material which is subject to strict conditions of use. Copyright in this material is owned by the New Zealand Standards Executive. Please read these terms and conditions carefully, as in addition to the usual range of civil remedies available to Standards New Zealand on behalf of the New Zealand Standards Executive for infringement of copyright, under New Zealand law every person who infringes copyright may be liable to a fine of up to \$10,000 for every infringing copy or imprisonment of up to 5 years, or a fine of up to \$150,000 or imprisonment not exceeding 5 years.

You have access to a single-user licence to read this non-revisable Adobe Acrobat PDF file and print out and retain ONE printed copy only.

We retain title and ownership of the copyright in this PDF file and the corresponding permitted printed copy at all times.

Under this license use of both the PDF file and the single permitted printed copy of this PDF file you may make are restricted to you. Under no circumstances are you permitted to save, sell, transfer, or copy this PDF file, the one permitted printed copy of this PDF file, or any part of either of them.

You undertake that you will not modify, adapt, translate, reverse engineer, decompile, disassemble or create derivative works based on any of the downloaded PDF file, nor will you merge it with any other software or document, even for internal use within your organization.

Under no circumstances may this PDF file be placed on a network of any sort without our express permission.

You are solely responsible for the selection of this PDF file and any advice or recommendation given by us about any aspect of this PDF file is intended for guidance only and is followed or acted upon entirely at your own risk.

We are not aware of any inherent risk of viruses in this PDF file at the time that it is accessed. We have exercised due diligence to ensure, so far as practicable, that this file does not contain such viruses.

No warranty of any form is given by us or by any party associated with us with regard to this PDF file, and you accept and acknowledge that we will not be liable in any way to you or any to other person in respect of any loss or damage however caused which may be suffered or incurred or which may arise directly or indirectly through any use of this PDF file.

Regardless of where you were when you received this PDF file you accept and acknowledge that to the fullest extent possible you submit to New Zealand law with regard to this licence and to your use of this PDF file.

One with the state of the state

## **COMMITTEE REPRESENTATION**

This standard was prepared under the supervision of the P4223 Committee the Standards Council established under the Standards Act 1988.

The committee consisted of representatives of the following organisations:

BRANZ Ltd Graeme Beattie

Glass Association of New Zealand Greg Yim
Insulating Glass Unit Manufacturers' Association Allan Sage

Ministry of Business, Innovation and Employment

Ministry of Business, Innovation and Employment

Ministry of Business, Innovation and Employment

Nick Locke

New Zealand Institute of Architects

Karl Jones

Window Association of New Zealand Darryl Mac

## **ACKNOWLEDGEMENT**

Standards New Zealand gratefully acknowledges the contribution of Darrel Cheong (Ministry of Business, Innovation and Employment), Michael Middlebrook (New Zealand Institute of Architects), and the time and expertise from all those involved in developing this standard.

## **COPYRIGHT**

The copyright of this document is the property of the Standards Council. No part of this document may be reproduced by photocopying or by any other means without the prior written permission of the Chief Executive of Standards New Zealand, unless the circumstances are covered by Part 3 of the Copyright Act 1994.

Standards New Zealand will vigorously defend the copyright in this standard. Every person who breaches Standards New Zealand's copyright may be liable, under section 131(5)(a) of the Copyright Act 1994, to a fine not exceeding \$10,000 for every infringing copy to which the offence relates, but not exceeding \$150,000 for the same transaction, or to imprisonment for a term not exceeding 5 years. Those in breach under section 131(5)(b) of the Copyright Act 1994 may be liable to a fine not exceeding \$150,000 or to imprisonment for a term not exceeding 5 years. If there has been a flagrant breach of copyright, Standards New Zealand may also seek additional damages from the infringing party, in addition to obtaining injunctive relief and an account of profits.

Published by Standards New Zealand, the trading arm of the Standards Council, Private Bag 2439, Wellington 6140. Telephone: (04) 498 5990, Fax: (04) 498 5994, Website: www.standards.co.nz.

AMENDMENTS						
No.	Date of issue	Description	Entered by, and date			

New Zealand Standard

## Glazing in buildings Part 2: Insulating glass units

Superseding NZS 4223.2:1985

## **NOTES**

Solone Sandra Man

## **CONTENTS**

Com	mitte	e representation	IFC		
Acknowledgement					
Copyright					
Refe	Referenced documents				
Latest revisions					
Review of standards					
Foreword					
Outcome statement					
Section					
1	GENERAL		1		
	1.1	Scope			
	1.2	Objective	1		
	1.3				
	1.4	Definitions			
2	2 MATERIALS		2		
3 DESIGN CRITERIA		GN CRITERIA	2		
	3.1	Design	2		
	3.2	Limitations			
4	GI A	AZING			
5		LITY ASSURANCE			
	5.1	Testing			
	5.2	Quality assurance procedures			
	5.3	Marking	5		

## REFERENCED DOCUMENTS

Reference is made in this document to the following:

## **New Zealand standards**

NZS 3504:1979 Specification for aluminium windows
NZS 3619:1979 Specification for timber windows

NZS 4223:--- Code of practice for glazing in buildings

Part 1:2008 Glass selection and glazing

Part 3:2016 Human impact safety requirements
Part 4:2008 Wind, dead, snow, and live actions

NZS 4232:---- Performance criteria for fire resisting enclosures

Part 2:1988 Fire resisting glazing systems

## Joint Australian/New Zealand standards

AS/NZS 4666:2012 Insulating glass units

AS/NZS 4668:2000 Glossary of terms used in the glass and glazing industry

## **International standards**

ISO 20492:---- Glass in buildings – Insulating glass

Part 1:2008 Durability of edge seals by climate tests

Part 2:2008 Chemical fogging tests

Part 3:2010 Gas concentration and gas leakage

Part 4:2010 Methods of test for the physical attributes of edge seals

## **American standards**

ASTM E2188-10 Standard test method for insulating glass unit performance

ASTM E2189-10 Standard test method for testing resistance to fogging in

insulating glass units

ASTM E2190-10 Standard specification for insulating glass unit performance

and evaluation

## **British standards**

BS EN 1279---- Glass in building. Insulating glass units

Part 1:2004 Generalities, dimensional tolerances and rules for the system

description

Part 2:2002 Long term test method and requirements for moisture

penetration

Part 3:2002 Long term test method and requirements for gas leakage rate

and for gas concentration tolerances

Part 4:2002 Methods of test for the physical attributes of edge seals

Part 6:2002 Factory production control and periodic tests

## **New Zealand legislation**

**Building Act 2004** 

Building Regulations 1992 (New Zealand Building Code (NZBC))

Clause B1 Structure

Clause B2 Durability

Clause F2 Hazardous building materials

Clause F4 Safety from falling

Clause H1 Energy efficiency

## **Websites**

www.building.govt.nz

www.legislation.govt.nz

## LATEST REVISIONS

The users of this standard should ensure that their copies of the above-mentioned standards are the latest revisions and include the latest amendments. Amendments to referenced New Zealand and joint Australian/New Zealand standards can be found on www.standards.co.nz.

## **REVIEW OF STANDARDS**

Suggestions for improvement of this standard will be welcomed. They should be sent to the Chief Executive, Standards New Zealand, Private Bag 2439, Wellington 6140.

## **FOREWORD**

NZS 4223 Part 2:1985 was originally withdrawn and replaced by AS/NZS 4666:2000. However, due to the style and complexity of this document it was never cited as a New Zealand Building Code compliance document by the former Department of Building and Housing (DBH now Building Performance, Ministry of Business, Innovation and Employment). In response, this new simplified Part 2 has been developed and added to the NZS 4223 set of standards to ensure insulating glass units used for glazing in buildings are fit for purpose.

NZS 4223.2 aligns and references AS/NZS 4666 for further information, including guidance on glazing and quality assurance.

The NZS 4223 set of standards provides procedures for glass selection and glazing in buildings subject to wind, dead, live, and snow actions, human impact safety requirements, and special applications such as overhead glazing, balustrades, and glass assemblies.

## **OUTCOME STATEMENT**

NZS 4223.2 is intended to provide a means of compliance with the relevant performance requirements of Building Code Clauses B1, B2, F2, F4, and H1 in order to minimise the potential for strength and durability failures of insulating glass units in buildings.

New Zealand Standard

## Glazing in buildings

## Part 2: Insulating glass units

## 1 GENERAL

## 1.1 Scope

This standard sets out requirements for materials, design, glazing, and quality assurance of insulating glass units (IGUs) for glazing in buildings.

The following are excluded from the scope of NZS 4223 Parts 1, 2, 3, and 4:

- (a) Glazing in lift cars and liftwells (refer to NZS 4223.1, Appendix A for guidance);
- (b) Furniture glass, cabinet glass, vanities, glass basins, refrigeration units, internal glass fitments and glass wall linings, framed internal wall mirrors, and mirrors not specifically covered by these parts;
- (c) Buildings and structures with no public access intended for non-habitable building structures for horticultural or agricultural use;
- (d) Restoration or repairs to existing decorated glass;
- (e) Glazing applications that might fail due to stresses other than tensile stresses, such as glass floors;
- (f) Plastic glazing materials;
- (g) The construction and installation of windows, (refer to NZS 3504, NZS 3619, and NZS 4232.2);
- (h) Glass blocks, pavers, slumped, formed, or cast glass;
- (i) Point-fixed or point-supported systems used for glazing, cladding, signage, and the like, not specifically covered by these parts (refer to Part 1 for design criteria and guidance for specific design).

## 1.2 Objective

NZS 4223.2 is intended to be used by the window industry, glaziers, designers, and specifiers of glass and glazing, and manufacturers and installers of insulating glass units (IGUs).

In some circumstances, the requirements of Parts 1, 3, and 4 of this standard may exceed the requirements of this part.

## 1.3 Interpretation

For the purposes of this standard, the word 'shall' refers to requirements that are essential for compliance with the standard, while the word 'should' refers to practices that are advised or recommended.

Notes to the text contain information and guidance and are not considered to be an integral part of the standard.

## 1.4 Definitions

For the purpose of this standard the following definition and those in NZS 4223 Parts 1, 3, and 4 apply. For further definitions refer to AS/NZS 4668 and AS/NZS 4666.

Insulating glass unit

Two or more panes of glass spaced apart and factory hermetically sealed with dry air or special gases in the unit cavity. Often abbreviated to IGU or referred to as 'the unit'

## 2 MATERIALS

Glass shall comply with NZS 4223.1 and glazing materials shall comply with AS/NZS 4666.

## 3 DESIGN CRITERIA

## 3.1 Design

Insulating glass units shall comply with:

- (a) Design criteria as set out in section 3 of NZS 4223.1;
- (b) Human impact safety requirements as set out in NZS 4223.3; and
- (c) Requirements for wind, dead, snow, and live actions as set out in NZS 4223.4.

## 3.2 Limitations

The limitations in 3.2.1 and 3.2.2 apply to insulating glass unit types.

## 3.2.1 Inclusions

The design criteria in 3.1 apply to the following types of units:

- (a) Hermetically sealed insulating glass units constructed with glass panes;
- (b) Insulating glass units with one or more cavity spaces, where the glass panes are parallel to each other;
- (c) Stepped edge insulating glass units; and
- (d) Insulating glass units containing introduced gases.

The glass panes may include float, patterned, wired, coated, laminated, toughened, heat-strengthened, sand blasted, acid etched, and ceramic enamel (fritted), or combinations of these glass types.

## 3.2.2 Exclusions to quality assurance

The design criteria in 3.1 shall apply to the following types of units. The quality assurance criteria in section 5 shall not apply to these types of units:

- (a) With non-glass panes;
- (b) Incorporating capillary/breather tubes or bladder devices (see note 1);
- (c) Containing lead-lights, copper lights, or other decorative glass inside the unit;
- (d) Incorporating internal venetian blinds, regardless of the control method;
- (e) Incorporating painted glass panes, where the paint is on the inside of the IGU;
- (f) Containing colonial, muntin, or spacer bar grids inside the unit (see note 2);
- (g) With plastic film adhered to any of the glass surfaces;
- (h) Where glass panes are not parallel to each other;
- (i) Containing a vacuum between the glass panes;
- (j) Containing point fixings in or through the unit; or
- (k) Incorporating heated panes.

## NOTE -

- (1) Appendix B of AS/NZS 4666 does, however, specify some aspects deemed essential for the inclusion of such elements.
- (2) Appendix H of AS/NZS 4666 does, however, specify some aspects deemed essential for the inclusion of such elements.
- (3) The manufacturer should be consulted about the quality assurance of speciality IGUs defined in (a) to (k).

## 4 GLAZING

Glazing shall be in accordance with AS/NZS 4666, section 3.

NOTE – Information is also provided in AS/NZS 4666 as follows:

- (a) Appendix E Principles of glazing;
- (b) Appendix F Glazing methods;
- (c) Appendix G Storage, handling, transport, and preservation.

## **5 QUALITY ASSURANCE**

## 5.1 Testing

## 5.1.1 General

This section sets out the system testing requirements for insulating glass units.

The units shall be tested by an independent, recognised testing facility and test results shall be available on request.

NOTE – Long-term testing regimes covered in 5.1 differ from daily factory floor periodic testing covered in 5.2 in that the testing regimes expose completed and fully cured units to long term cyclic, accelerated weathering, and UV tests that utilise laboratory-based criteria. This is often known as 'type testing' or IGU 'system testing', and the actual components used to make the IGU are defined in the 'system description' as part of the test procedure.

## 5.1.2 Test standards

## 5.1.2.1

Insulating glass units shall be tested in accordance with either:

- (a) ASTM E2188; or
- (b) BS EN 1279-2; or
- (c) ISO 20492-1.

## 5.1.2.2

Gas filled insulating glass units shall also be tested in accordance with the principles and procedures specified in either:

- (a) BS EN 1279-3; or
- (b) ISO 20492-3.

## 5.1.2.3

Insulating glass units shall also comply with the principles and procedures in either:

- (a) ASTM E2189 and E2190; or
- (b) BS EN 1279-1 and BS EN 1279-4; or
- (c) ISO 20492-2 and ISO 20492-4.

NOTE – Independent, third-party product certification may be used by a manufacturer to demonstrate ongoing manufacturing compliance of insulating glass units against the manufacturer's quality system and this standard (see 5.2).

## 5.1.3 Acceptable period between tests

Compliance testing in accordance with 5.1.2 shall be conducted at least every 2 years.

NOTE – Test results will normally be for 'system testing' and not the actual IGU system description used for each project.

## 5.2 Quality assurance procedures

Quality assurance testing and recording criteria for components and the assembly of insulating glass units shall comply with:

- (a) AS/NZS 4666 section 5; or
- (b) The principles and procedures set out in BS EN 1279-6.

NOTE – Compliance is normally achieved by third party certification. The Insulating Glass Unit Manufacturers' Association (IGUMA) BS EN 1279-6 manual is an example of this certification.

## 5.3 Marking

Insulating glass units shall be permanently and clearly marked.

As a minimum, marking shall include the following:

- (a) Manufacturer's or supplier's name or trademark; and
- (b) The date of manufacture (use the year as the minimum).

NOTE -

- (1) Marking is normally at the edge of the IGU and within the glazing rebate so the unit can be identified in case of failure. Therefore edge labels within the glazing rebate are considered to be permanent.
- (2) Additional marking may be used by the manufacturer.

## **NOTES**



# 

## © 2016 STANDARDS COUNCIL

Approved by the Standards Council on 19 February 2016 to be a New Zealand standard pursuant to the provisions of section 10 of the Standards Act 1988.

First published: 29 February 2016

The following references relate to this standard:

Project No. P4223

Draft for comment No. DZ 4223.2

Typeset by: Standards New Zealand



